

Abstract geometric shapes in white outline, including a large semi-circle on the left, a horizontal line, and a series of connected line segments forming a stylized 'N' or 'M' shape at the bottom.

ATTACHMENT H

Investigation – Infrastructure Assessment

Leader Street Bakery Code Amendment Infrastructure Assessment

Leader Street Bakery Code Amendment Infrastructure Assessment

Prepared For:
Harmony Property Investments



Prepared By:
Building Services Engineers

Document Issue
Project Number
Document Date

3
20210683
10 October 2023



Sydney | Brisbane | Melbourne | Canberra | Adelaide

BSE | Building Services Engineers

ABN | 24 084 076 200

Level 2, 121 Walker Street
North Sydney NSW 2060

Phone | 02 9922 5200

Email | sydney@bse.com.au

Web | www.bse.com.au

Status

Document Title	Leader Street Bakery Code Amendment Infrastructure Assessment		
Project Manager:	Orlando Cavuoto		
Document Author:	Orlando Cavuoto		
Revision	Revision	Date	Reviewer
	1	31 Aug. 23	RM
	2	21 Sep. 23	OC
	3	10 Oct. 23	OC
Issued To:	Lauren Talifero		

Contents

1.	Introduction	5
1.1.	Purpose & scope	5
1.2.	Referenced documents	5
2.	Electrical Services.....	6
2.1.	Existing Electrical Infrastructure	6
2.2.	Proposed Electrical Infrastructure	6
2.3.	SAPN Infrastructure	7
2.4.	Telecommunications Infrastructure	7
3.	Hydraulic Services	8
3.1.	Existing Hydraulic Infrastructure.....	8
3.2.	Proposed Hydraulic Infrastructure	9
3.1.	Proposed Natural Gas Infrastructure.....	10
3.2.	SA Water infrastructure.....	10
4.	Fire Protection Services	11
4.1.	Existing Fire Protection Infrastructure	11
4.2.	Proposed Fire Protection Services	11
4.3.	SA Water Infrastructure.....	11
4.4.	South Australian Metropolitan Fire Service (SAMFS).....	11
4.5.	Comment.....	11
5.	Appendix A – Maximum Demand Calculation	12

1. Introduction

1.1. Purpose & scope

The purpose of this document is to detail the specific existing conditions of the Goodman Fielder Site located at 4 Leah Street Forestville and establish the infrastructure requirements for future multi building/ multi storey residential class 2 development

This document details the extent of engineering services included in BSE's Scope Review of existing services infrastructure (electrical, telecommunications, water supply, sewerage and Gas) servicing the site currently tenanted by Goodman Fielder and evaluating suitability for a change of use to predominantly multi storey residential with potential small scale non residential uses. relating to:

- Electrical services
- Communication service
- Fire services
- Hydraulic services

1.2. Referenced documents

AS/NZS 3000	Wiring rules
AS 3008	Selection of cables
AS/NZS 3500	National plumbing and drainage codes, part 1-5
AS 1680	Interior lighting
AS 1668	The use of ventilation and air conditioning in buildings
AS 2444-2001	Portable fire extinguishers and fire blankets
AS 2441	Installation of fire hose reels where upgraded
AS 2419	Fire hydrant installation
AS/ NZS 2293	Emergency lighting and exit signage
	Building Code of Australia
	Workplace Health and Safety regulations

2. Electrical Services

2.1. Existing Electrical Infrastructure

The Goodman Fielder site is currently provided with power from an above ground transformer located on the upper level of the existing warehouse on Leader Street. The Transformer is supplied by the SAPN 11kV network via transmission cables also on Leader Street. Currently the transformer provides in excess of 1500kVA site.



Figure 1 - Existing SAPN Transformer (Leader Street)

Based on the age and location of the transformer it is unlikely that any potential reuse for future development will be possible. As such a complete abandonment of the existing transformer will be required prior to the construction of the new facility.

2.2. Proposed Electrical Infrastructure

As part of the assessment and based on the current electrical standard AS3000 "Wiring Rules" and NCC 2022 a maximum demand based on the proposed density layouts and services has been conducted. Based on a assumed high density application and associated carparking and the recent addition to of Electric Vehicle charging station requirement to class 2 apartment buildings the overall maximum demand for the site is as follows.

Building Designation	Maximum Demand (kVA)
High Density Application	500
Carpark (Including EV Charging)	670
25% Spare Capacity	290
Total	1460

As part of the above calculation no diversity of operation has been allowed for the EV charging which make up approximately 90% of the total carpark electrical requirements. In Addition there are numerous manufacturers of smart charging systems that can undertake load shedding and/or increase the amount of power allocated to car changing during times when power to the site is more abundant (generally overnight).

Based on the above it can be seen that future development is not likely to exceed the current power currently being delivered to site. Please refer to appendix A for details of indicative electrical maximum demand.

2.3. SAPN Infrastructure

SAPN have indicated that as the project is not currently under consideration for construction in the immediate future that no assessment of infrastructure is required. Upon application of a submission for a power supply augmentation an assessment of the existing infrastructure will be made. Furthermore as the indicative maximum demand does not exceed the current demand a future change of use is suitable for this site.

Additionally based on the current plans to undertake construction of the former Le Cornu Site it is unlikely that at the time of works commencing on the current Goodman Fielder Site that the current electrical infrastructure will still be in its current form.

As such based on the above the current power supply being delivered to site is sufficient for future residential schemes.

2.4. Telecommunications Infrastructure

The current site is served by a single NBN connection located on Leah Street. This existing connection is likely unsuitable for any future development and will be required to be altered in the future to suit any changes to the site. As such NBN have indicated that any changes to connections will be assessed during detailed documentation period, however there is existing infrastructure within the area that could be utilised for any future development.

3. Hydraulic Services

3.1. Existing Hydraulic Infrastructure

Currently the existing site is serviced by three (3) metered connections located on First Avenue (50mm metered connection), Leader Street (20mm metered connection) and on Leah Street (50mm metered connection).




Figure 2 - Existing Metered Connections

The site is also serviced by eight (8) Sewerage connections. A 100mm connection that enters the sewer main on First Avenue, a 100mm connection on Leah Street, and an additional six (6) connections that were installed to the site pre 1930 that the dimensions are unknown.




Figure 3 - Existing Sewerage Connections

3.1. Proposed Natural Gas Infrastructure

The existing 80mm mains within Leah Street and Leader Street have sufficient capacity for future development. Based on a high density development it is expected that the maximum gas demand will be in the order of 12,000MJ (no diversity allowed for) well below the current requirements of the bakery.

As with all infrastructure entering the site locations of new meters and entry points will be coordinated during detailed design and coordinated with APA.

3.2. SA Water infrastructure.

All SA Water infrastructure within the surrounding streets is adequate for the future development. Additionally, based on the Le Cornu development it is likely that the existing street infrastructure will be upgraded to accommodate the future residential development. SA Water have indicated that detailed assessment of network will be conducted upon completion of the proposed future design.

4. Fire Protection Services

4.1. Existing Fire Protection Infrastructure

The current building is not supplied with any dedicated water feed to serve as a dedicated fire protection system. As such it is expected that all water that would be utilised to fight a potential fire in the existing building would be taken from the existing street plugs located on Leader and Leah Street.

4.2. Proposed Fire Protection Services

Based on potential future high density development of the site the following fire protection items can be accommodated by the existing SA Water Infrastructure.

The fire protections system of and high desity building effectively can be designed with minimal water supply from the street mains and supplemented by onsite storage tanks, pumps and boosters. Based on the typical high density applications up to 5 storeys the calculations have been undertaken to determine the water supply requirements to adequately fight a fire within a future development Flow rate required would be approximately 32L/s @ 200kPa. As such it will likely be required that a 150mm fire water mains connection be installed off of Leader Street to supply the proposed fire systems.

4.3. SA Water Infrastructure

Currently within Leader Street side there is a 250mm Ductile Iron Lined Pipe that would be utilised as water supply in the event of a fire. At this stage no flow test or network analysis has been conducted as the results of said tests only valid for 12 months. However based on the flow and pressure requirements within the building it is likely that both tanks and pumps will be required to be installed as part of the construction. Additionally future development of the Le Cornu site will likely have significant infrastructure impacts on the area in general and as such assessment of the system would be required during detailed design. It must be noted that all the existing infrastructure in Leader street is compliant with SA Water requirements for a multi storey residential building.

4.4. South Australian Metropolitan Fire Service (SAMFS)

The SAMFS have indicated that as the project is only very conceptual that no formal approval can be granted. Each new development is assessed on its merits and endorsed when adequate architecture and fire protections systems have been designed.

4.5. Comment

Based on the requirement for the future site and current inground SA Water infrastructure the proposed fire safety solution will be likely be acceptable upon review of detailed documentation by the SAMFS.

5. Appendix A – Maximum Demand Calculation

ELECTRICAL DEMAND CALCULATOR To SAPN TS100 A.3 and AS/NZS 3000												
CLIENT: Harmony					calc by: AK		date: 28 Feb 2022					
PROJECT:					amended by: OC		date: 21 Sep 2023					
JOB No:					check by:		date:					
							assumed PF	0.90	L&P			
								0.80	HVAC			
					subtotal - existing:		0	kW	0	kVA	0	A
					subtotal - proposed		930	kW	1166	kVA	1690	A
					TOTAL:		930	kW	1166	kVA	1690	A
Proposed Loads												
Description	Type of Occupancy		No,		ADMD							
Proposed high density Occupancy	Residential	L & P	91		4	kVA	327.6	kW	364.0	kVA	528	A
		EV	18		7.36		0.0	kW	132.5	kVA	192	A
		Special			Describe load			kW	0.0	kVA	0	A
Carpark	EV	EV	91		7.36	kVA	602.8	kW	669.8	kVA	971	A
							0.0	kW	0.0	kVA	0	A
		Special			Describe load			kW	0.0	kVA	0	A